CODE ANALYSIS

APPLICABLE CODES

	Year		Year
International Building Code	2006	National Electrical Code	2008
International Mechanical Code	2006	Uniform Code for	
International Plumbing Code	2006	Building Conservation	
International Fire Code	2006	ADA Accessibility	
International Energy Conservation Code	2006	Guidelines	

A. Occupancy and Group: _____ _____ _____ _____ _____

Change in Use: Yes _____ No _____ Mixed Occupancy: Yes _____ No _____
Special Use and Occupancy (e.g. High Rise, Covered Mall): _____

B. Seismic Design Category: _____ Design Wind Speed: _____ mph

C. Type of Construction (circle one):

I/A I/B II/A II/B III/A III/B IV/HT V/A V/B

D. Fire Resistance Rating Requirements for the Exterior Walls based on the fire separation distance (in hours):

North: _____ South: _____ East: _____ West: _____

E. Mixed Occupancies: _____ Nonseparated Uses: _____

F: Sprinklers:

Required: _____ Provided: _____ Type of Sprinkler System: _____

G: Number of Stories: _____ Building Height: _____

H: Actual Area per Floor (square feet): _____

I: Tabular Area: _____

J: Area Modifications:

a) $A_a = A_t + \left[\frac{A_t\ I_f}{100}\right] + \left[\frac{A_t\ I_s}{100}\right]$ $\qquad I_f = 100\left[\frac{F}{P} - 0.25\right]\frac{W}{30}$

b) Sum of the Ratio Calculations for Mixed Occupancies:

$$\frac{\text{Actual Area}}{\text{Allowable Area}} \leq 1$$

c) Total Allowable Area for:

1) One Story: _____
2) Two Story: $A_a(2)$_____
3) Three Story: $A_a(3)$_____

d) Unlimited Area Building: Yes _____ No _____ Code Section: _____

K. Fire Resistance Rating Requirements for Building Elements (hours).

Element	Hours	Assembly Listing	Element	Hours	Assembly Listing
Exterior Bearing Walls			Floors - Ceiling Floors		
Interior Bearing Walls			Roofs - Ceiling Roofs		
Exterior Non-Bearing Walls			Exterior Doors and Windows		
Structural Frame			Shaft Enclosures		
Partitions - Permanent			Fire Walls		
Fire Barriers			Fire Partitions		
			Smoke Partitions		

L. Design Occupant Load: _____

Exit Width Required: _____ Exit Width Provided: _____

M. Minimum Number of Required Plumbing Facilities:

a) Water Closets - Required (m) _____ (f) _____ Provided (m) _____ (f) _____
b) Lavatories - Required (m) _____ (f) _____ Provided (m) _____ (f) _____
c) Bath Tubs or Showers: _____
d) Drinking Fountains: _____ Service Sinks: _____

FOOTNOTES:

1) In case of conflict with the U.S. Department of Justice Federal Registers Parts I through V - ADA Guidelines and specific reference to the International Building Code Accessibility Chapters, the more restrictive requirement shall govern.

2) Additional Code Information shall be provided at the discretion of the Building Official for Complex Buildings. Including, but not limited to:

a) High Rise Requirements.
b) Atriums.
c) Performance Based Criteria.
d) Means or Egress Analysis.
e) Fire Assembly Locator Sheet.
f) Exterior and Interior Accessibility Route.
g) Fire Stopping, Including Tested Design Number.

UTAH NATIONAL GUARD
DRAPER HEADQUARTERS
ROOFTOP UNIT ADDITION
DFCM# 09019480

DRAWING INDEX:



WHW ENGINEERING INC.
PROFESSIONAL MECHANICAL ENGINEERING
8619 Sandy Parkway Suite 101
SANDY, UTAH 84070
(801)466-4021, FAX 465-8536
EMAIL: excellence@whw-engineering.com

PROFESSIONAL ENGINEER
03/12/09
WINWARD M. PACKER
No. 375080
STATE OF UTAH

MECHANICAL ENGINEER
WHW ENGINEERING, INC.
8619 SANDY PARKWAY
SUITE 101
SANDY, UTAH 84075
PHONE: (801) 466-4021 FAX: (8O1) 466-8536

MECHANICAL LEGEND

SYMBOL	ABR.	DESCRIPTION
GENERAL TERMINOLOGY		
A / ME-101		SECTION LETTER DESIGNATION / SECTION DRAWN ON THIS SHEET
A2		DETAIL NUMBER DESIGNATION CORRESPONDING WITH GRID LOCATION
1 / AH		MECHANICAL EQUIPMENT DESIGNATION / EQUIPMENT ITEM DESIGNATION
CFM / D-1		REGISTER, GRILL OR DIFFUSER DESIGNATION WITH BALANCING CFM LISTED BELOW
R-1		GRILLE, OR LOUVER DESIGNATION WHERE BALANCING NOT REQUIRED
1		REVISION DESIGNATOR AND NUMBER
1		KEY NOTE DESIGNATOR AND NUMBER
	POC	POINT OF CONNECTION
	POR	POINT OF REMOVAL
AFF		ABOVE FINISHED FLOOR
AP		ACCESS PANEL
℄ EL.		CENTER LINE ELEVATION
INV. ELEV.		INVERT ELEVATION
GC		GENERAL CONTRACTOR
MC		MECHANICAL CONTRACTOR
ATC		CONTROL CONTRACTOR
EC		ELECTRICAL CONTRACTOR
FPC		FIRE PROTECTION CONTROL
NIC		NOT IN CONTRACT
NTS		NOT TO SCALE
VCP		VITRIFIED CLAY PIPE
C		COMMON
NC		NORMALLY CLOSED
NO		NORMALLY OPEN

SYMBOL	ABR.	DESCRIPTION
AIR SIDE		
		EXISTING AIR DUCT TO BE REMOVED
		EXISTING AIR DUCT TO REMAIN
		NEW AIR DUCT
		NEW SPIRAL DUCT
		NEW MEDIUM PRESSURE DUCT
		RECT. TO RECT. AIR DUCT TAKE-OFF
		RECT. TO RND. AIR DUCT TAKE-OFF
		RND. TO RND. AIR DUCT TAKE-OFF
		RECT. TAKE-OFF AT END OF MAIN
		MEDIUM PRESSURE TAKE-OFF
		FLEXIBLE AIR DUCT
		LINED DUCT
		VANED ELBOW
		RADIUS ELBOW
		CONCENTRIC DUCT TRANSITION
		ECCENTRIC DUCT TRANSITION
		FLEXIBLE AIR DUCT CONNECTION
VD		VOLUME DAMPER
		SUPPLY AIR DIFFUSER
		RETURN AIR, FRESH AIR, AND TRANSFER AIR
		CEILING MOUNTED EXHAUST FAN OR EXHAUST GRILLE
		RETURN OR OUTSIDE AIR DUCT UP
		SUPPLY DUCT UP
		EXHAUST AIR INTAKE UP
		RETURN OR OUTSIDE AIR DUCT DOWN
		SUPPLY DUCT DOWN
		EXHAUST DUCT DOWN
		ROUND DUCT UP
		LOWER DUCT DOWN
R		RAISE DUCT UP
D		LOWER DUCT DOWN
		FLEXIBLE DUCT CONNECTION
		PARALLEL BLADE DAMPER
		OPPOSED BLADE DAMPER
H H		HUMIDIFIER
		AIRFLOW MEASURING STATION
		FILTER BANK
		COIL
	AP	ACCESS PANEL
		EXISTING EQUIPMENT TO BE REMOVED
		EXISTING EQUIPMENT TO REMAIN
		NEW EQUIPMENT
A	BD	AUTOMATIC BACKDRAFT DAMPER
F	FS	FIRE & SMOKE DAMPER
T / RTU-1	T-STAT	WALL MOUNTED THERMOSTAT MECHANICAL EQUIPMENT CONTROLLED
SA		SUPPLY AIR
RA		RETURN AIR
EA		EXHAUST AIR
OA		OUTSIDE AIR
MA		MIXED AIR
FA		FRESH AIR
RF		RELIEF AIR

SYMBOL	ABR.	DESCRIPTION
WET SIDE CONT		
		PITCH DOWN
		ELBOW UP
		ELBOW DOWN
		TEE UP
		TEE DOWN
		EXISTING PIPING TO REMAIN
		NEW PIPING

GENERAL NOTES:

G-1 MECHANICAL INFORMATION IS NOT LIMITED TO THE MECHANICAL DRAWINGS. CONTRACTOR SHALL BE RESPONSIBLE FOR INFORMATION ON ALL OTHER CONSTRUCTION DOCUMENTS INCLUDING DRAWINGS BY OTHER DISCIPLINES AND SPECIFICATIONS.

A - EACH DRAWING SHEET AND THE SPECIFICATIONS HAVE BEEN PREPARED TO SUPPLEMENT EACH OTHER AND THEY SHALL BE INTERPRETED AS AN INTEGRAL UNIT WITH ITEMS SHOWN AND NOTED ON ONE AND NOT THE OTHER BEING FURNISHED AND INSTALLED AS THOUGH SHOWN AND CALLED OUT IN ALL PLACES. ITEMS IN SPECIFICATIONS OR DRAWINGS LISTED WHICH ARE DIFFERING IN EFFICIENCY OR QUALITY SHALL BE HELD TO THE GREATEST OF: EFFICIENCY, QUALITY OR GOVERNING CODE.

B - THE CONTRACTOR WILL BE HELD RESPONSIBLE FOR THE INSTALLATION OF THE SYSTEMS ACCORDING TO THE TRUE INTENT AND MEANING OF THE CONTRACT DOCUMENTS.

C - THE CONTRACTOR SHALL INSTALL ALL EQUIPMENT WITH PROPER SERVICE ACCESS AND CLEARANCES ACCORDING TO MANUFACTURERS RECOMMENDATIONS. THE CONTRACTOR SHALL REVIEW SUPPLIERS BID PACKAGES FOR COMPLETENESS AND COMPLIANCE TO THE SPECIFICATIONS, SCHEDULES, AND DESIGN INTENT (ALL EQUIPMENT AND METHODS). THE CONTRACTOR SHALL REMOVE AND REINSTALL CORRECTLY AT HIS OWN EXPENSE ANY EQUIPMENT NOT IN COMPLIANCE.

D - THE CONTRACTOR SHALL CONSULT MANUFACTURERS INSTALLATION INSTRUCTIONS FOR SIZES, METHODS, ACCESSORIES, AND CLEARANCES IN SPACE AVAILABLE PRIOR TO BIDDING PROJECT.

E - ANYTHING NOT CLEAR OR IN CONFLICT WILL BE EXPLAINED BY MAKING APPLICATION TO THE ENGINEER IN WRITING.

G-2 ANY AND ALL ALTERATIONS TO THE SYSTEM SHOWN SHALL BE SUBMITTED TO THE ENGINEER PRIOR TO CHANGES FOR APPROVAL. CONTRACTOR SHALL NOT START ANY CHANGES UNTIL NOTIFIED IN WRITING. IF CHANGES ARE MADE PRIOR TO APPROVAL CONTRACTOR SHALL TAKE ALL RESPONSIBILITY FOR THE CHANGES MADE AND ALL COSTS RELATING TO FAILURE OR REPLACEMENT OF ALTERATIONS.

G-3 CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS AND LOCATIONS.

G-4 THE WORKING DRAWINGS ARE DIAGRAMMATIC. THEY DO NOT SHOW EVERY OFFSET, BEND, OR ELBOW NECESSARY FOR THE COMPLETE INSTALLATION IN THE SPACE PROVIDED. ALL LOCATIONS FOR MECHANICAL EQUIPMENT SHALL BE FIELD VERIFIED AND COORDINATED WITH ALL DRAWINGS. THE CONTRACTOR SHALL PROVIDE OR COORDINATE WITH THE GENERAL CONTRACTOR PROVISIONS FOR BLOCKOUTS OR CORE DRILLS THROUGH STRUCTURE.

G-5 THE INSTRUCTION TO "PROVIDE" ALSO INCLUDES INSTALLATION.

G-6 MECHANICAL CONTRACTOR SHALL PROVIDE AND INSTALL SMOKE AND FIRE DAMPERS AS REQUIRED BY LOCAL CODES AND AUTHORITIES.

G-7 SHEET METAL DUCT SIZES SHOWN ON DRAWINGS ARE FREE AREA DIMENSIONS.

G-8 PROVIDE AND INSTALL BALANCING DAMPERS IN ALL SUPPLY AND EXHAUST AIR BRANCH DUCTS. BALANCE TO CFM SHOWN ON PLAN.

G-9 SEE ARCHITECTURAL REFLECTED CEILING PLAN FOR EXACT LOCATION OF DIFFUSERS AND GRILLES.

G-10 PROVIDE TURNING VANES IN ALL ELBOWS OF RECTANGULAR DUCT.

G-11 THE CONTRACTOR SHALL ASSUME ALL RESPONSIBILITY IN HANDLING AND DISPOSING OF REFRIGERANTS, OILS, ETC. ALL SUCH MATERIALS SHALL BE HANDLED, DISPOSED, AND USED IN ACCORDANCE WITH ALL LOCAL, STATE, AND FEDERAL LAWS.

G-12 THE MECHANICAL CONTRACTOR SHALL VERIFY MOTOR VOLTAGES WITH THE ELECTRICAL DRAWING BEFORE ORDERING MOTORIZED EQUIPMENT AND CONTROLS.

G-13 C.F.M. LISTED IS ACTUAL AIR.

G-14 SUPPLIERS SHALL REVIEW ALL DRAWINGS AND THE SPECIFICATIONS PRIOR TO SUBMITTING PRICES TO THE CONTRACTOR. ALL QUESTIONS AND DISCREPANCIES SHALL BE BROUGHT TO THE ENGINEERS ATTENTION PRIOR TO BIDDING.

G-15 CONTRACTOR SHALL THOROUGHLY REVIEW AND SIGN SUBMITTALS FOR COMPLETENESS AND COMPLIANCE TO THE SPECIFICATIONS PRIOR TO ENGINEERS REVIEW. SUPPLIERS SHALL HIGHLIGHT OR MARK ALL INFORMATION REQUIRED TO SHOW COMPLIANCE TO THE SPECIFICATIONS. ALL REQUESTED EXCEPTIONS TO THE SPECIFICATIONS, OR SCHEDULES SHALL BE CLEARLY NOTED AND EXPLAINED. SUBMITTAL REVIEW AND ACCEPTANCE IS FOR DESIGN CONCEPT ONLY, AND DOES NOT AT ANY TIME RELIEVE THE CONTRACTOR OF RESPONSIBILITY TO MEET SPECIFICATIONS, CAPACITIES, OR DESIGN INTENT.

G-16 ALL MECHANICAL SHALL BE INSTALLED AND CONFORM TO THE 2006 EDITION OF THE IMC WITH UTAH ANNOTATIONS AND LOCAL AUTHORITY REQUIREMENTS.

G-17 THIS CONTRACTOR SHALL BE RESPONSIBLE FOR THE DRAINING DOWN AND RE-FILLING OF ALL SYSTEMS NECESSARY TO COMPLETE THE WORK OUTLINED BY THIS PROJECT. THIS INCLUDES PROVIDING THE REQUIRED CHEMICAL TREATMENT WHEN RE-FILLING THE SYSTEM.

G-18 ALL PIPING, MATERIALS, ETC. SHALL BE NEW AND DOMESTIC MADE UNLESS SPECIFICALLY AUTHORIZED IN WRITING PRIOR TO BID.

G-19 THIS CONTRACTOR SHALL HIRE A LICENSED DESIGN BUILD ELECTRICIAN TO CONNECT NEW EQUIPMENT TO EXISTING POWER. ELECTRICAL WORK AND CONNECTIONS TO NEW EQUIPMENT SHALL MATCH ELECTRICAL WORK TO EXISTING EQUIPMENT ON SITE. ALL ELECTRICAL WORK SHALL COMPLY WITH 2008 NEC, AS WELL AS UTAH NATIONAL GUARD, AND DFCM DESIGN AND CONSTRUCTION STANDARDS.

WHW ENGINEERING INC.
PROFESSIONAL MECHANICAL ENGINEERING
8619 Sandy Parkway Suite 101
SANDY, UTAH 84070
(801)466-4021, FAX 466-8536
EMAIL: excellence@whw-engineering.com

CONSULTANTS

PROJECT NAME & ADDRESS

DRAPER NATIONAL GUARD ROOF-TOP ADDITION

DRAPER, UTAH

MARK	DATE	REVISION

PROJECT MANAGER: WP
DRAWN BY: STAFF
CHECKED BY: WP
DATE: 03/12/09
DFCM JOB NO.: 09019480

PROFESSIONAL ENGINEER 03/12/09 WINWARD M. PACKER No. 375080 STATE OF UTAH

SHEET TITLE

MECHANICAL GENERAL NOTES AND LEGEND

SHEET NO.

MG001



SHEET NOTES:

1. PROVIDE AUTO BACK DRAFT DAMPERS AT EVERY DUCT THAT PENETRATES ROOF FROM RT-1, RT-2, RT-3, AND RT-4.
2. EXISTING FIRE SMOKE DAMPER TO REMAIN.

GENERAL NOTES:

1. ALL DUCT WORK THIS PLAN IS EXISTING TO REMAIN.
2. THIS CONTRACTOR SHALL HIRE A LICENSED DESIGN BUILD ELECTRICIAN TO CONNECT NEW EQUIPMENT TO EXISTING POWER. ELECTRICAL WORK AND CONNECTIONS TO NEW EQUIPMENT SHALL MATCH ELECTRICAL WORK TO EXISTING EQUIPMENT ON SITE. SEE SHEET MG001 GENERAL NOTE G-19.

MECHANICAL MEZZANINE PLAN

SCALE: 1/4" = 1'-0"

WHW ENGINEERING INC.
PROFESSIONAL MECHANICAL ENGINEERING
8619 Sandy Parkway Suite 101
SANDY, UTAH 84070
(801)466-4021, FAX 466-8536
EMAIL: excellence@whw-engineering.com

CONSULTANTS

COPYRIGHT NOTICE

PROJECT NAME & ADDRESS

DRAPER NATIONAL GUARD ROOF-TOP ADDITION

DRAPER, UTAH

MARK	DATE	REVISION

PROJECT MANAGER: WP
DRAWN BY: STAFF
CHECKED BY: WP
DATE: 03/12/09
DFCM JOB NO.: 09019480

PROFESSIONAL ENGINEER 03/12/09 WINWARD M. PACKER No. 375080 STATE OF UTAH

SHEET TITLE

MECHANICAL MEZZANINE PLAN

SHEET NO.

ME101



MECHANICAL ROOF PLAN

SCALE: 1/4" = 1'-0"

SHEET NOTES:

1. CONNECT TO EXISTING WATER PIPING AT THIS APPROXIMATE LOCATION. FIELD VERIFY. ROUTE NEW WATER PIPING TO NEW HUMIDIFIERS. PROVIDE INSULATION AND HEAT TRACING AT ALL EXPOSED WATER, STEAM, AND CONDENSATE PIPING FOR HUMIDIFIERS.
2. ROUTE STEAM PIPING TO STEAM INJECTOR IN DUCT WORK. SEE DETAIL ON ME501. SIZE PER MANUFACTURERS RECOMMENDATIONS.
3. PROVIDE NEW PRE-FILTER RACK AND NEW PRE-FILTERS FOR THIS UNIT. ADJUST MOTOR SHEAVES AS NECESSARY TO ACCOMMODATE HIGHER PRESSURE DROP.
4. REPLACE ECONOMIZER THIS UNIT.
5. EXISTING ROOF TOP UNIT SHALL REMAIN.
6. EXISTING HUMIDIFIER SHALL REMAIN.
7. PROVIDE NEW ROOF MOUNTED HUMIDIFIER UNDER SERVICE PLATFORM. INSTALL PER MANUFACTURERS GUIDELINES. PROVIDE SUPPORTS AND ROOF CONNECTIONS TO MATCH EXISTING HU-2.
8. PROVIDE NEW ROOF TOP UNIT. INSTALL ON EXISTING SERVICE PLATFORM. PROVIDE ALL ADDITIONAL SUPPORTS, ACCESSORIES, ETC. AS REQUIRED. FIELD VERIFY EXACT SIZE AND LOCATION OF EXISTING OPENINGS. CONNECT TO EXISTING DUCT STUB-OUTS THROUGH ROOF WITH FLEXIBLE CONNECTORS. SEE SECTIONS, DETAILS, SCHEDULES, AND SPECS FOR MORE INFORMATION.

GENERAL NOTES:

1. THIS CONTRACTOR SHALL HIRE A LICENSED DESIGN BUILD ELECTRICIAN TO CONNECT NEW EQUIPMENT TO EXISTING POWER. ELECTRICAL WORK AND CONNECTIONS TO NEW EQUIPMENT SHALL MATCH ELECTRICAL WORK TO EXISTING EQUIPMENT ON SITE. ELECTRICAL PANELS FOR ROOF TOP UNITS ARE LOCATED IN ROOM BELOW. ELECTRICAL PANEL FOR HUMIDIFIERS ARE LOCATED ON ROOF NEW HUMIDIFIER HU-2.

WHW ENGINEERING INC.
PROFESSIONAL MECHANICAL ENGINEERING
8619 Sandy Parkway Suite 101
SANDY, UTAH 84070
(801)466-4021, FAX 466-8536
EMAIL: excellence@whw-engineering.com

CONSULTANTS

PROJECT NAME & ADDRESS

DRAPER NATIONAL GUARD ROOF-TOP ADDITION

DRAPER, UTAH

MARK	DATE	REVISION

PROJECT MANAGER: WP
DRAWN BY: STAFF
CHECKED BY: WP
DATE: 03/12/09
DFCM JOB NO.: 09019480

PROFESSIONAL ENGINEER
03/12/09
WINWARD M. PACKER
No. 375080
STATE OF UTAH

SHEET TITLE

MECHANICAL ROOF PLAN

SHEET NO.

ME102



MECHANICAL ROOF PLAN SECTION

SCALE: 1/4" = 1'-0"



MECHANICAL SECTION

SCALE: 1/4" = 1'-0"

SHEET NOTES:

1. SEE SHEET ME501 FOR HUMIDIFIER PIPING DETAIL.
2. PROVIDE AUTO BACK DRAFT DAMPERS AT EVERY DUCT THAT PENETRATES ROOF FROM RT-1, RT-2, RT-3, AND RT-4.
3. EXISTING FIRE SMOKE DAMPER TO REMAIN.
4. EXISTING ROOF TOP UNITS RTU-1 AND RTU-2 SHALL REMAIN. MAKE REPAIRS AS NOTED ON SHEET ME101.
5. PROVIDE NEW ROOF TOP UNITS.

GENERAL NOTES:

1. PROVIDE ALL WATER, STEAM AND CONDENSATE PIPING WITH INSULATION.
2. PROVIDE ALL WATER AND CONDENSATE PIPING WITH HEAT TRACE.
3. THIS CONTRACTOR SHALL HIRE A LICENSED DESIGN BUILD ELECTRICIAN TO CONNECT NEW EQUIPMENT TO EXISTING POWER. ELECTRICAL WORK AND CONNECTIONS TO NEW EQUIPMENT SHALL MATCH ELECTRICAL WORK TO EXISTING EQUIPMENT ON SITE.

WHW ENGINEERING INC.
PROFESSIONAL MECHANICAL ENGINEERING
8619 Sandy Parkway Suite 101
SANDY, UTAH 84070
(801)466-4021, FAX 466-8536
EMAIL: excellence@whw-engineering.com

CONSULTANTS

PROJECT NAME & ADDRESS

DRAPER NATIONAL GUARD ROOF-TOP ADDITION

DRAPER, UTAH

MARK	DATE	REVISION

PROJECT MANAGER: WP
DRAWN BY: STAFF
CHECKED BY: WP
DATE: 03/12/09
DFCM JOB NO.: 09019480

PROFESSIONAL ENGINEER 03/12/09 WINWARD M. PACKER No. 375080 STATE OF UTAH

SHEET TITLE

MECHANICAL SECTIONS

SHEET NO.

ME401

ROOFTOP AIR CONDITIONER SCHEDULE (GAS HEAT)

SYMBOL	MANUFACTURER & MODEL NUMBER	SA CFM	OSA CFM	E.S.P./ T.S.P. IN W.G.	HEATING	COOLING			ELECTRICAL							EER @ ARI	OPER. WT. (LBS)	SCHEDULE NOTES
					TOT. MIN. INPUT MBH	AMB. AIR (DB)	AMB. AIR (WB)	MIN. TOTAL MBH	V - Ø - Hz	COMPRESSOR #	COMPRESSOR TOTAL RLA	EVAP BLOWER HP	POWER EXHAUST HP	MCA	MOCP			
RT 1	AAON RM-030-3-0-AB02-000 SERIAL: 200701-AMCT04023	EXISTING																
RT 2	AAON RM-030-3-0-AB02-000 SERIAL: 200805-AMCT06024	EXISTING																
RT 3	AAON RN-030-3-0-AA02-000:CFGE-E0B-DEL-C0C-SB0ADB0-00-00000000B	10500	3150	1.75 / 3.82	N/A	95	65	314	460/3/60	2	21.8	15	3 HP x 2	87	100	10.6	3100	1,2,3,4,5
RT 4	AAON RN-030-3-0-AA02-000:CFGE-E0B-DEL-C0C-SB0ADB0-00-00000000B	10500	3150	1.75 / 3.82	N/A	95	65	314	460/3/60	2	21.8	15	3 HP x 2	87	100	10.6	3100	1,2,3,4,5

1. E.S.P. DOES NOT INCLUDE LOSSES THROUGH ACCESSORIES.
2. RATED MINIMUM INPUT AT SEA LEVEL.
3. PROVIDE ONE 15 AMP, 120 VOLT, DUPLEX GFCI SERVICE OUTLET. FACTORY INSTALLED, FIELD WIRED.
4. BELT DRIVE UNIT
5. PROVIDE SMOKE DETECTOR IN SUPPLY AND RETURN.
6. PROVIDE WITH 30% PRE-FILTERS, AND 98% EFFICIENT POST FILTER SECTION. PROVIDE WITH FILTER GAUGE, AND TIE INTO EXISTING BUILDING CONTROLS SYSTEM BY UTAH CONTROLS FOR MONITORING.
7. PROVIDE ALL CONTROLS AND ACCESSORIES AS NEEDED TO TIE INTO EXISTING BUILDING CONTROLS SYSTEM BY UTAH CONTROLS. INCLUDE A MINIMUM OF 1 NEW CONTROL BOARD WITH EXPANDED CAPACITY.



1 ATMOSPHERIC STEAM PIPING DETAIL
NO SCALE

STEAM HUMIDIFIERS

MARK	MAKE AND MODEL	SERVES	CFM	STEAM		ELECTRICAL DATA			DUCT	NOTES
				MAX PSIG	LBS/ HR	V-Ø-Hz	RATED INPUT (kW)	MAX FUSE		
HU 1	NORTEC NHTC-030	RT-1	10,500	80	30	460/3/60	11.4	25	50/22	1,2,3,4
HU 2	NORTEC NHTC-030	EXISTING								
HU 3	NORTEC NHTC-030	RT-3	10,500	80	30	460/3/60	11.4	25	50/22	1,2,3,4
HU 4	NORTEC NHTC-030	RT-4	10,500	80	30	460/3/60	11.4	25	50/22	1,2,3,4

1. PROVIDE DUCT DISPERSION UNIT. INSTALL PER DETAILS AND MANUFACTURERS RECOMMENDATIONS.
2. SEE SPECIFICATIONS FOR APPROVED MANUFACTURERS.
3. HUMIDIFIER SHALL BE ALL STAINLESS STEEL CONSTRUCTION.
4. DUCT SIZE IS APPROXIMATE. FIELD VERIFY BEFORE ORDERING.
5. HUMIDIFIERS AND ASSOCIATED SUPPLY AND DRAIN LINES SHALL BE TIED INTO EXISTING BUILDING CONTROLS SYSTEM BY UTAH CONTROLS.



2 BEAM THROUGH DUCT PENETRATION DETAIL
NO SCALE

WHW ENGINEERING INC.
PROFESSIONAL MECHANICAL ENGINEERING
8619 Sandy Parkway Suite 101
SANDY, UTAH 84070
(801)466-4021, FAX 466-8536
EMAIL: excellence@whw-engineering.com

CONSULTANTS

PROJECT NAME & ADDRESS

DRAPER NATIONAL GUARD ROOF-TOP ADDITION

DRAPER, UTAH

MARK	DATE	REVISION

PROJECT MANAGER: WP
DRAWN BY: STAFF
CHECKED BY: WP
DATE: 03/12/09
DFCM JOB NO.: 09019480

PROFESSIONAL ENGINEER 03/12/09 WINWARD M. PACKER No. 375080 STATE OF UTAH

SHEET TITLE
MECHANICAL DETAILS AND SCHEDULES

SHEET NO.
ME501